

ADDENDUM #1
IRON HORSE SHELTER & BATHROOMS

REVISE TO READ THE FOLLOWING:

Concrete floor will be flat in the picnic area trowel finished smooth and no less than **5" thick**
Mechanical room and both bathrooms will have floor drain centered in room with **5" thick** floor
sloped to floor drain

Contractor responsible for measuring distance to water and sewer. It is available at the site, but exact
distance is unknown.